



NOTES:

1. OPENING IN CONCRETE WALL SHALL BE CORED USING HIGH SPEED DIAMOND DRILL
2. ALL METAL FIXTURES SHALL BE OF STAINLESS STEEL
3. SERVICE LINE SHALL BE FLUSH WITH THE INSIDE OF THE CONCRETE PIPE OR WALL
4. IF TRUNK LINE DIAMETER IS LESS THAN 24" THEN A SADDLE TYPE CONNECTION WILL BE USED

Location: \\eng\ACAD_STD\Technical Details\B - Sewer Details\B-05 - Typical Field Connection to Large Concrete Pipe or Concrete Manhole.dwg
 Plotted on: Tuesday, January 15, 2013 - 1:21 PM by Donohoe, William



Boston Water and Sewer Commission

980 HARRISON AVE., BOSTON, MA 02119
 (617) 989-7000 www.bwsc.org

TYPICAL FIELD CONNECTION TO LARGE CONCRETE PIPE OR CONCRETE MANHOLE

Scale: Not To Scale

DATE:
 June 30, 2012

DETAIL NO.
B-05